

**TABLE 5-11
INSULATION OF DUCTS**

Duct Location	Climate Zone	Group R Occupancy Heating or Cooling Ducts
On roof or on exterior of building	1	E and W
	2	D and W
Attic, garage, crawl space, in walls ¹ , in floor/ceiling ¹	1	E
	2	E
Within the conditioned space or in heated basements		None Required
In cement slab or in ground		B

Note: Where ducts are used for both heating and cooling, the minimum insulation shall be as required for the most restrictive condition.

- 1 Insulation may be omitted on that portion of a duct which is located within a wall or floor/ceiling space where both sides of this space are exposed to conditioned air and where this space is not ventilated or otherwise exposed to unconditioned air.
- 2 Vapor barriers shall be installed on conditioned air supply ducts in geographic areas where the average of the July, August and September mean dewpoint temperature exceeds 60°F.

INSULATION TYPES: Minimum densities and out-of-package thickness.

- A. 0.5-inch 1.5 to 2 lb/cu. ft. duct liner, mineral or glass fiber blanket or equivalent to provide an installed total thermal resistance of at least R-2.
- B. 2-inch 0.60 lb/cu. ft. mineral or glass fiber blanket, 1.5-inch 1.5 to 2 lb/cu. ft. duct liner, mineral or glass fiber blanket. 1.5-inch 3 to 7 lb/cu. ft. mineral or glass fiber board or equivalent to provide an installed total thermal resistance of at least R-5.
- C. 3-inch 0.60 lb/cu. ft. mineral or glass fiber blanket, 2-inch 1.5 to 2 lb/cu. ft. duct liner, mineral or glass fiber blanket. 2-inch 3 to 7 lb/cu. ft. mineral or glass fiber board or equivalent to provide an installed total thermal resistance of at least R-7.
- D. 4-inch 0.60 lb/cu. ft. mineral or glass fiber blanket, 3-inch 1.5 to 2 lb/cu. ft. duct liner, mineral or glass fiber blanket. 3-inch 3 to 7 lb/cu. ft. mineral or glass fiber board or equivalent to provide an installed total thermal resistance of at least R-10.
- E. 3.5-inch 0.60 lb/cu. ft. mineral or glass fiber blanket, 2.5-inch 1.5 to 2 lb/cu. ft. duct liner, mineral or glass fiber board or equivalent to provide an installed total thermal resistance of at least R-8.
- V. Vapor barrier, with perm rating not greater than 0.5 perm, all joints sealed.
- W. Approved weatherproof barrier.